



الشركة السعودية للكهرباء

SEC DISTRIBUTION CONSTRUCTION STANDARDS

	SDCS-01	
Dated:	24-06-2003	





DRW.141-OC10SFS, 10M, SELF SUPPORT, LOW VOLTAGE, MEDIUM ANGLE STRUCTURE 16°-60°

ALL DIMENSIONS ARE IN MILLIMETER



الشركة السعودية للكهرباء

SEC DISTRIBUTION CONSTRUCTION STANDARDS

SDCS-01

ERIAL	QTY BILL OF MATERIALS DESCRIPTION		REFERENCES	
NO.	1	OC10SFS - 10 Meter Steel Pole, Self Support, HDG, Single Circuit	20-SDMS-01	Page 39
02	1	Suspension Clamp For Quadruplex Messenger	20-SDMS-02	Fig. 31
03	1	Shoulder Eye Bolt M16x300mmW/2 Nuts, 1 Flat Washer & 1 Spring Washer		
	1	Anchor Shackle	20-SDMS-02	
04				
05	1	Eye Nut M16	20-SDMS-02	Fig. 18
06	2	Cable Ties	20-SDMS-02	Fig. 63
	4			


DRW.141A-OC10SFS, 10M, SELF SUPPORT, LOW VOLTAGE, MEDIUM ANGLE STRUCTURE 16°-60°



الشركة السعودية للكهرباء

SEC DISTRIBUTION CONSTRUCTION STANDARDS

	SDCS-01				
Dated:	24-06-2003				



DRW.142-OC10SFS, 10M, SELF SUPPORT, LOW VOLTAGE, HEAVY ANGLE STRUCTURE 61°-90°

ALL DIMENSIONS ARE IN MILLIMETER

Saudi Electricity Company () الشركة السعودية للكهرباء



SEC DISTRIBUTION CONSTRUCTION STANDARDS

SDCS-01

Dated: 24-06-2003					
SERIAL NO.	QTY	BILLS OF MATERIALS DESCRIPTION		REFERENCES	
01	1	OC10SFS — 10 Meter Steel Pole, Self Support, HDG, Single Circuit	20-SDMS-01	Page 39	
02	2	Strain Clamp, Straight Line Deodend Type for Quadruplex Messenger	20-SDMS-02	Fig. 30	
03	1	Shoulder Eye Bolt M16x300mmW/2 Nuts,1 Flot Wosher & 1 Spring Wosher	20-SDMS-02	Fig. 16	
04	1	Eye Nut M16	20-SDMS-02	Fig. 18	
05	2	Coble Tie	20-SDMS-02	Fig. 63	
06	4	Porollel Groove Comp. Connector for 120mm2 Quodruplex Messenger	20-SDMS-02	Fig. 39	
07	3	Insuloting Cop for Quodruplex Messenger	20-SDMS-02	Fig. 40	


DRW.142A-OC10SFS, 10M, SELF SUPPORT, LOW VOLTAGE, HEAVY ANGLE STRUCTURE 61°-90°




الشركة السعودية للكهرباء

SEC DISTRIBUTION CONSTRUCTION STANDARDS

	SDCS-01	
Dated:	24-06-2003	





DRW.143-OC10SFS, 10M, SELF SUPPORT, LOW VOLTAGE, TERMINAL STRUCT.

ALL DIMENSIONS ARE IN MILLIMETER



الشركة السعودية للكهرباء

SEC DISTRIBUTION CONSTRUCTION STANDARDS

SDCS-01

Dated:

24-03-2003

SERIAL NO.	QTY	BILL OF MATERIALS DESCRIPTION	REFERENCE	s
01	1	OC10SFS - 10 Meter Steel Pole, Self Support, HDG, Single Circuit	20-SDMS-01	Page 39
02	1	Strain Clamp, Straight Line Deadend Type For Quadruplex Messenger	20-SDMS-02	Fig. 30
03	1	Shoulder Eye Bolt M16x300mmW/2 Nuts,1 Flat Washers & 1 Spring Washer	20-SDMS-02	Fig. 16
04	1	Eye Nut M16	20-SDMS-02	Fig. 18
05	1	Cable Ties	20-SDMS-02	Fig. 63

DRW.143A-OC10SFS, 10M, LOW VOLTAGE, SELF SUPPORT, TERMINAL STRUCT.